

EC DECLARATION OF CONFORMITY

IN ACCORDANCE WITH EN ISO STANDARDS SHOWN BELOW:

ISSUE NO: RM-FF001 January 2016

Roof-Maker Ltd
1 Pinfold Road,
Thurmaston
Leicester
LE4 8AS

Product: Fixed Flat aluminium and glass rooflight
for flat roof installation (*with a pitch of 5° - 15°*)

Essential Characteristics	Performance	Test Standards	Tested by	Relevant Standard
Air Permeability	600pa	BS EN 1026:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
	Class 4	BS EN 12207:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
Water Tightness	1200pa	BS EN 1027:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
	Class E1200	BS EN 12208:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
Wind Resistance	2400pa	BS EN 12211:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
	CE 2400	BS EN 12210:2000	Chiltern Dynamic	BS 6375 Pt 1: 2009
Dead Load	1.52kN/m ²	BS EN 1991-1-1	Wintech Lab	BS EN 1991-1-1
Structural use of glass	Pass	pr EN 16612:2013	Wintech Lab	Pr EN 16612:2103
Whole Product U Value	0.6 W/m ² K	BS EN 10077-2	BM TRADA	EN 14351-1: 2006
Whole Product U Value	0.6 W/m ² K	SAP Calc method	Wintech Lab	
Thermal Transmittance Triple	0.6 W/m ² K	EN 673-2011 Ug value	Calumen II	EN 673-2011
Sound insulation		EN/ISO 717-1/A1		
Glass Unit Manufacture	Pass	EN 1279 Pt 2, 3	CEN Solutions	EN 1279 Pt 2, 3
Toughened Safety Glass	Pass	EN 12150-1:2000		

This declaration of performance is issued under the sole responsibility of Roof-Maker Ltd.

Sabahudin Medic
Quality Manager
Date: 11/01/2016



Andrew Huddleston
CEO
Date: 11/01/2016

